



CROSS STREETS

E 91ST STE 92ND STCITY OF NEW YORK
FIRE DEPARTMENT

A-10(B) 10-03

BATTALION 34

D.O. 34

E 683465

VIOLATION ORDER

To 1395 LEXINGTON AVE NY, NY 10128

ADDRESS

2,3, MEZ

ROOM NO. OR FLOOR

BUSINESS

TYPE OF OCCUPANCY

THE YOUNG MEN'S AND YOUNG
WOMEN'S HEBREW ASSOCIATION
NAME OF OWNER, LEASEE, OCCUPANT, ETC.

ACCOUNT NO.

An inspection this date of the above premises indicates the existence of the following violations under the enforcement jurisdiction of this Department. You are hereby directed to correct such violations by compliance with the following order:

EXISTING CONDITIONS

STANDARD ORDER FORM NO.	ITEM NO.	
		MODIFIED CLASS J & C.O.C.
FA-04-01	1	FAILED TO SUCCESSFULLY CONDUCT ACCEPTANCE TEST WITNESSED BY A FIRE DEPARTMENT REPRESENTATIVE FROM THE FIRE ALARM INSPECTION UNIT FOR THE FIRE ALARM SYSTEM.
COMMENTS:		(A) FAILED TO SHUTDOWN AC UNIT ON 2 ND FL MEZZ NORTH ME.R.
		(B) FAILED TO REPAIR/REPLACE DEFECTIVE ELEV. RECALL LIGHTS FOR ALL 3 ELEV. CARS. (C) FAILED TO REPAIR/REPLACE NOTIFICATION DEVICES TO ACTIVATE UPON ACTIVATION OF ALARM ON 2 ND FL MEZZ NORTH LOCKER ROOM AREA. (SPLAKER/STROBE) AND 3 ^{FL} SOUTH NEXT TO STAIR F (STROBE)
REMEDY:		SUBMIT A REQUEST (B-45 FORM) TO THE FIRE DEPARTMENT FIRE ALARM INSPECTION UNIT TO SCHEDULE AN INSPECTION/TEST OF THE FIRE ALARM SYSTEM, IN ACCORDANCE WITH FC901.5.

If this order has not been complied with in, 30 days of the issuance date, A SUMMONS will be served for violations of the Administrative Code of the City of New York.

TO 25

FOR -NUMBERING

TO 24

FOR DISMISSAL

By Order of the Fire Commissioner

This is to certify that I have made an inspection of said premises and have issued the above order to:

ADAM SADOWSKI
NAME OF PERSON WHO RECEIVED THIS ORDER

BLOG. ENGINEER 917-502-4349

TITLE

PHONE #

K. AKHAND

INSPECTOR

01/18/2023

DATE

F.A.J.U.

UNIT

Unit Address 9 METROTECH CENTER
BROOKLYN, NY, 11201

Unit Telephone 718-999-1554



CROSS STREETS

97TH STREET98TH STREETCITY OF NEW YORK
FIRE DEPARTMENT

A-10(B) 10-03

BATTALION _____

D.O. 34

E 683456

VIOLATION ORDER

To 97-01 NORTHERN BLVD, QUEENS, NY-11368 PLATINUM
C,1 BUSINESS 42179374
ROOM NO. OR FLOOR TYPE OF OCCUPANCY ACCOUNT NO.
(OAK STREET HEALTH)

An inspection this date of the above premises indicates the existence of the following violations under the enforcement jurisdiction of this Department. You are hereby directed to correct such violations by compliance with the following order:

FDNY # 2021-TMFALM-005817-PLAN

STANDARD ORDER FORM NO.	ITEM NO.	MANUAL & AUTOMATIC SMOKE/CO DETECTION & SPRINKLER ALARM SYSTEM WITH CUC (GROUP B (BUSINESS, LU-R) FAS)
FA-01-02A	1	FAILED TO COMPLETE THE INSTALLATION OF AN APPROVED TYPE OF FIRE ALARM SYSTEM CONSISTENT WITH THE DESIGNATED AND/OR ACTUAL OCCUPANCY OF THE BLDG., IN VIOLATION OF FC901.4 & 901.2
COMMENTS:		FAILED TO CORRECT ALL DEFICIENCIES LISTED IN THE NOTICE OF DEFECT ISSUED ON 08/30/2022 FOR THE FIRE ALARM SYSTEM TESTED UNDER ABOVE MENTIONED JOB.
REMEDY:		CORRECT ALL DEFICIENCIES LISTED IN THE ENCLOSED NOTICE OF DEFECT AND SUBMIT A REQUEST (FORM B-45) TO THE FIRE DEPARTMENT FIRE ALARM INSPECTION UNIT TO SCHEDULE AN INSPECTION AND/OR TEST TO VERIFY THAT SUCH DEFICIENCIES HAVE BEEN CORRECTED, IN ACCORDANCE FC 901.4 AND 901.2.

If this order has not been complied with in, 30 days of the issuance date, A SUMMONS will be served for violations of the Administrative Code of the City of New York.

TO 25

FOR-NUMBERING

TO 24

FOR DISMISSAL

By Order of the Fire Commissioner



This is to certify that I have made an inspection of said premises and have issued the above order to:

JUVENTINO MORALES GC 646-804-9534
NAME OF PERSON WHO RECEIVED THIS ORDER TITLE PHONE #
K. AKHAND 01/05/2023 F.A.I.U.
INSPECTOR DATE UNIT

Unit Address 9 METROTECH CENTER Unit Telephone 718-999-1554
BROOKLYN, NY-11201